



39 MAIN STREET | SAUNEMIN, IL 61769 | PH 815.832.4421 | FAX 815.832.4435 | WWW.SAUNEMIN.ORG

Saunemin Community Consolidated School District #438
Lead in Drinking Water – Summary of Sampling
October 4 & October 6, 2017

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
SBS-1	Baseball Field	DF - Drinking Fountain	First Draw	20.8 ppb
SBF-1	Baseball Field	DF - Drinking Fountain	Flush	ND
SBS-2	Concession Stand	KS - Kitchen Sink	First Draw	6.77 ppb
SBF-2	Concession Stand	KS - Kitchen Sink	Flush	ND
SS-1	Room 102 - pre-K	S - Sink	First Draw	11.2 ppb
SF-1	Room 102 - pre-K	S - Sink	Flush	ND
SS-2	Main Corridor by Office	DF - Drinking Fountain	First Draw	ND
SF-2	Main Corridor by Office	DF - Drinking Fountain	Flush	ND
SS-3	2nd Floor Landing	DF - Drinking Fountain	First Draw	ND
SF-3	2nd Floor Landing	DF - Drinking Fountain	Flush	ND
SS-4	3rd Floor Landing	DF - Drinking Fountain	First Draw	ND
SF-4	3rd Floor Landing	DF - Drinking Fountain	Flush	ND
SS-5	Main Hall by Boiler Room	DF - Drinking Fountain	First Draw	ND
SF-5	Main Hall by Boiler Room	DF - Drinking Fountain	Flush	ND
SS-6	Kitchen - Dishwashing Sink	KS - Kitchen Sink	First Draw	ND
SF-6	Kitchen - Dishwashing Sink	KS - Kitchen Sink	Flush	ND
SS-7	Kitchen - Vegetable Prep Sink	KS - Kitchen Sink	First Draw	ND
SF-7	Kitchen - Vegetable Prep Sink	KS - Kitchen Sink	Flush	ND
SS-8	Kitchen - Food Prep Sink	KS - Kitchen Sink	First Draw	ND
SF-8	Kitchen - Food Prep Sink	KS - Kitchen Sink	Flush	ND
SS-9	Corridor by Gym	DF - Drinking Fountain	First Draw	23.1 ppb
SF-9	Corridor by Gym	DF - Drinking Fountain	Flush	13.6 ppb
SS-10	Fitness Center	DF - Drinking Fountain	First Draw	ND
SF-10	Fitness Center	DF - Drinking Fountain	Flush	ND
SS-11	Concessions - Left	KS - Kitchen Sink	First Draw	12.3 ppb
SF-11	Concessions - Left	KS - Kitchen Sink	Flush	2.28 ppb
SS-12	Concessions - Right	KS - Kitchen Sink	First Draw	3.09 ppb
SF-12	Concessions - Right	KS - Kitchen Sink	Flush	ND
SS-13	Fitness Center Weight Room	DF - Drinking Fountain	First Draw	ND
SF-13	Fitness Center Weight Room	DF - Drinking Fountain	Flush	ND
SS-14	Community Library	S - Sink	First Draw	5.34 ppb
SF-14	Community Library	S - Sink	Flush	2.34 ppb
ND = None Detected				